



中国国家强制性产品认证证书

证书编号: 2024010305681651

认证委托人名称及地址

建兴电机株式会社

(Jang-an-dong) 183, Hancheon-ro, Dongdaemun-gu, Seoul, Korea

生产者名称及地址

建兴电机株式会社

(Jang-an-dong) 183, Hancheon-ro, Dongdaemun-gu, Seoul, Korea

生产企业名称及地址

建兴电机株式会社

(Jang-an-dong) 183, Hancheon-ro, Dongdaemun-gu, Seoul, Korea

产品名称和系列、型号、规格

按钮开关

KH-2201, KH-2202, KH-2204 (型号解释详见附页); Uimp: 1.5kV; Ui: 500V;
Ue: 250V/125V; Ie: 6A/10A; Ith: 10A; 使用类别: AC-15; 安装孔径: $\Phi 22$; IP56 (仅
KH-2201-11R、KH-2204L-111R), IP50

产品标准和技术要求

GB/T 14048.5-2017

上述产品符合《强制性产品认证实施规则 低压电器 低压元器件》
(CNCA-C03-02:2024) 的要求, 特发此证。

发证日期: 2024 年 09 月 02 日 有效期至: 2029 年 09 月 01 日

证书信息和有效性可扫描下方二维码或登录发证机构网站查验,
也可在认监委网站 (www.cnca.gov.cn) 查询。



签发:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司





中国国家强制性产品认证证书

证书编号: 2024010305681651

证书附页: 第 1 页 共 2 页

型号的解释:

KH-2201□-□□-□ 控制按钮开关

④ ① ② ③

① number of NO contacts

② number of NC contacts

③ R: red | G: green | Y: yellow | O: orange | W: white | B: blue

④ Button Type::

S: Selectable push button

EB: Emergency push button

ER: Emergency push lock, turn reset

AT: Push lock, push return

Blank: Push button

注: ①、②、③项内容可不在铭牌上标识, 仅在包装箱上标识。

KH-2202-□-□□ 选择按钮开关

① ② ③

① 2S: 2 step manual return short lever | 3S: 3 step manual return short lever | 2L: 2 step manual return long lever | 3L: 3 step manual return long lever | 2AS: 2 step auto-return short lever | 3AS: 3 step auto-return short lever | 3RS: 3 step left-manual, right-auto-return short lever | 2AL: 2 step auto-return long lever | 3AL: 3 step auto-return long lever | 3RL: 3 step left-manual, right-auto-return long lever | 2K: 2 step manual-return key switch | 3K: 3 step manual-return key switch | 2AK: 2 step auto-return key switch | 3AK: 3 step auto-return key switch | 3RK: 3 step left-manual, right-auto-return key switch

② number of NO contacts

③ number of NC contacts

注: ②、③项内容可不在铭牌上标识, 仅在包装箱上标识。

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



中国国家强制性产品认证证书

证书编号: 2024010305681651

证书附页: 第 2 页 共 2 页

KH-2204□□-□ □□□ 指示按钮开关

①⑥ ② ③④⑤

① -: filament lamp | L: LED lamp

② Input voltage: 1: AC 110V 50/60Hz | 2: AC 220V 50/60Hz | 3: AC 230V 50/60Hz |
TL: AC/DC 24/12/6.3(filament lamp)/6V(LED lamp)

③ number of NO contacts

④ number of NC contacts

⑤ R: red | G: green | Y: yellow | O: orange | W: white | B: blue

⑥ Button Type:

EB: Emergency push button

ER: Emergency push lock, turn reset

AT: Push lock, push return

Blank: Push button

注: ③、④、⑤项内容可不在铭牌上标识, 仅在包装箱上标识。

本页为证书附页, 应与证书主页同时使用。



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

中国质量认证中心有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

CERTIFICATE NO.: 2024010305681651

NAME AND ADDRESS OF THE APPLICANT

KUN HUNG ELECTRIC CO.,LTD.

(Jang-an-dong)183,Hancheon-ro,Dongdaemun-gu, Seoul, Korea

NAME AND ADDRESS OF THE MANUFACTURER

KUN HUNG ELECTRIC CO.,LTD.

(Jang-an-dong)183,Hancheon-ro,Dongdaemun-gu, Seoul, Korea

NAME AND LOCATION OF THE FACTORY

KUN HUNG ELECTRIC CO.,LTD.

(Jang-an-dong)183,Hancheon-ro,Dongdaemun-gu, Seoul, Korea

PRODUCT NAME,MODEL AND SPECIFICATION

Push-button Switch

KH-2201,KH-2202,KH-2204; Uimp:1.5kV ; Ui:500V ; Ue:250V/125V ; Ie:6A/10A ; Ith:10A ; AC-15 ;
Φ22 ; IP56(KH-2201-11R、 KH-2204L-111R) , IP50

STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

Valid from: Sep.02,2024

Valid until: Sep.01,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



SIGNATURE:

谢肇煦



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.





CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010305681651

Appendix: Page 1 of 2

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

型号的解释:

KH-2201□-□□-□ 控制按钮开关

④ ① ② ③

① number of NO contacts

② number of NC contacts

③ R: red | G: green | Y: yellow | O: orange | W: white | B: blue

④ Button Type::

S: Selectable push button

EB: Emergency push button

ER: Emergency push lock, turn reset

AT: Push lock, push return

Blank: Push button

注: ①、②、③项内容可不在铭牌上标识, 仅在包装箱上标识。

KH-2202-□-□□ 选择按钮开关

① ② ③

① 2S: 2 step manual return short lever | 3S: 3 step manual return short lever | 2L: 2 step manual return long lever | 3L: 3 step manual return long lever | 2AS: 2 step auto-return short lever | 3AS: 3 step auto-return short lever | 3RS: 3 step left-manual, right-auto-return short lever | 2AL: 2 step auto-return long lever | 3AL: 3 step auto-return long lever | 3RL: 3 step left-manual, right-auto-return long lever | 2K: 2 step manual-return key switch | 3K: 3 step manual-return key switch | 2AK: 2 step auto-return key switch | 3AK: 3 step auto-return key switch | 3RK: 3 step left-manual, right-auto-return key switch

② number of NO contacts

③ number of NC contacts

注: ②、③项内容可不在铭牌上标识, 仅在包装箱上标识。

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO. : 2024010305681651

Appendix: Page 2 of 2

本翻译文件不具有法律效力，
不得单独使用
This translated document
does not have legal validity and
cannot be used in isolation

KH-2204□□-□ □□□ 指示按钮开关

①⑥ ② ③④⑤

① -: filament lamp | L: LED lamp

② Input voltage: 1: AC 110V 50/60Hz | 2: AC 220V 50/60Hz | 3: AC 230V 50/60Hz |
TL: AC/DC 24/12/6.3(filament lamp)/6V(LED lamp)

③ number of NO contacts

④ number of NC contacts

⑤ R: red | G: green | Y: yellow | O: orange | W: white | B: blue

⑥ Button Type:

EB: Emergency push button

ER: Emergency push lock, turn reset

AT: Push lock, push return

Blank: Push button

注: ③、④、⑤项内容可不在铭牌上标识, 仅在包装箱上标识。

This page is attached to the certificate and should be used at the same time as the certificate page.



中国质量认证中心
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.