



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

CERTIFICATE NO.: 2015010305778937

NAME AND ADDRESS OF THE APPLICANT

KUN HUNG ELECTRIC CO.,LTD.
(Jang-an-dong)183,Hancheon-ro,Dongdaemun-gu, Seoul, Korea

NAME AND ADDRESS OF THE MANUFACTURER

KUN HUNG ELECTRIC CO.,LTD.
(Jang-an-dong)183,Hancheon-ro,Dongdaemun-gu, Seoul, Korea

NAME AND ADDRESS OF THE FACTORY

KUN HUNG ELECTRIC CO.,LTD.
(Jang-an-dong)183,Hancheon-ro,Dongdaemun-gu, Seoul, Korea

PRODUCT NAME, MODEL AND SPECIFICATION

Push-button Switch

NF30 series; Uimp:6kV; Ui:600V; Ith:10A; AC-15:Ue/Ie:250V/6A、125V/10A; DC-13:Ue/Ie:24V/6A; AC-15, DC-13; ϕ 30mm; IP54(W), IP40(non- W);

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T14048.5-2017

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification(REFNO.CNCA-C03-02:2014).

Valid from: Jun.13,2019

Valid until: Jun.02,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original issued: Jun.02,2015

The certificate information is available through CNCA's website: www.cnca.gov.cn



President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE



中国国家强制性产品认证证书

附 录

第 1 页 共 1 页

证书编号: 2015010305778937

纸 号: 2320435

型号解释:

NF 30 □ □ — □ □ □ □ □ □
① ② ③ ④ ⑤ ⑥ ⑦ ⑧ ⑨

① Mounting hole 安装孔径: $\Phi 30$

② Guard Type 防护材料类型 G: Plastic Guard type 塑料护罩型,

Blank: Aluminum Guard type 铝制护罩

③ W: 防护等级 IP54, Blank: 防护等级 P40

④ Product Type 产品类型: P(Pushbutton switch 按钮开关), B(Illuminated Push Button Switch 照明按钮开关), S(Selector Switch 选择开关), K(Key Selector Switch 钥匙开关)

⑤ Operation System 操作系统:

M(Push Button 按钮), A(Push Lock & Push Reset 推锁和复位),

EM(Mushroom Headed Push Button 蘑菇头按钮, Momentary 瞬时),

EA(Mushroom Headed Push Button 蘑菇头按钮, Alternate 备用), ER(Push Button, 按钮 Turn to Reset 转复位); 2(2

Positions Manual Selector Switch 2 个位置手动选择开关), 3(3 Positions Manual Selector Switch 3 个位置手动选择开关),

A2(2 Positions Auto Selector Switch 2 个位置自动选择开关), A3(3 Positions Auto Selector Switch 3 个位置自动选择开关),

3R(3 Positions Left Lock & Right Auto Return Selector Switch 3 个位置左锁和右自动返回选择开关)

⑥ Input Voltage 指示灯输入电压:

1A (AC110V 50/60Hz), 2A(AC220V 50/60Hz), 1C[AC(50/60Hz)/DC 6V], 2C[AC(50/60Hz)/DC 12V],

3C[AC(50/60Hz)/DC 24V]

⑦ Button Color 按钮颜色: R(Red 红), G(Green 绿), Y(Yellow 黄), W(White 白), B(Blue 蓝), O(Orange 橙)

⑧ Contact Block 常开触点数量:

1(Normally Open (NO) contact 1 Each), 2(Normally Open (NO) contact 2 Each)

⑨ Contact Block 常闭触点数量:

1(Normally Closed (NC) contact 1 Each), 2(Normally Closed (NC) contact 2 Each)

注: 此附录与证书同时使用时有效。



主 任:

陆 楠



中国质量认证中心



中国国家强制性产品认证证书

证书编号: 2014010305732954

委托人名称、地址

建兴电机株式会社

(Jang-an-dong) 183, Hancheon-ro, Dongdaemun-gu, Seoul, Korea

生产者(制造商)名称、地址

建兴电机株式会社

(Jang-an-dong) 183, Hancheon-ro, Dongdaemun-gu, Seoul, Korea

生产企业名称、地址

建兴电机株式会社

(Jang-an-dong) 183, Hancheon-ro, Dongdaemun-gu, Seoul, Korea

产品名称和系列、规格、型号

安全门开关

KSD-A、KSD-B、KSD-2B、KSD-AB; Uimp:4kV; Ui:500V; Ue/le:AC250V/3A, DC250V/0.27A; Ith:10A; AC-15, DC-13; IP67

产品标准和技术要求

GB/T14048.5-2017

上述产品符合强制性产品认证实施规则 CNCA-C03-02:2014 的要求,
特发此证。

发证日期: 2019 年 06 月 13 日 有效期至: 2024 年 06 月 13 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书为变更证书, 证书首次颁发日期: 2014 年 11 月 04 日

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



主任:

陆楠



中国质量认证中心