



Product Service

EC-Attestation of Conformity

No. N8 07 07 54505 033

Holder of Certificate: KUN HUNG ELECTRIC CO., LTD.113-4, Jangan-Dong, Dongdaemoon-Gu
SEOUL 130-100
REPUBLIC OF KOREA**Product: Low voltage switchgear combination
(Pilot Lamp)**

This EC-Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA0122587



Date, 2007-07-11



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2

**EC-Attestation of Conformity**

No. N8 07 07 54505 033

Model(s):

KPL 25 a - b c d, KPL 30 a - b c d

a. IP Code

Blank: IP40

W: IP65

b. Lamp type

Blank: Incandescent lamp

L: LED lamp

x. Input voltage of lamp

1A: 110 V a.c.; 50/60 Hz

2A: 220 V a.c.; 50/60 Hz

3A: 230 V a.c.; 50/60 Hz

1C: 6 V a.c./ d.c.

2C: 12 V a.c./ d.c.

3C: 24 V a.c./ d.c.

y. Lamp color

R: Red

G: Green

Y: Yellow

W: White

B: Blue

Parameters:

Rated input voltage: 110/220/230 V a.c.

Rated insulation voltage: 250 V a.c./d.c

Rated impulse withstand voltage: 4 KV

Degree of protection: IP40 of IP65

Pollution degree: 3

Overvoltage category: III

Remark:

When installing/inserting the equipment
all requirements of the mentioned test standards
must be fulfilled.**Tested
according to:**

EN 60947-1:2004

EN 60947-5-1:2004