



Product Service

EC-Attestation of Conformity

No. N8 07 07 54505 035

Holder of Certificate: KUN HUNG ELECTRIC CO., LTD.113-4, Jangan-Dong, Dongdaemoon-Gu
SEOUL 130-100
REPUBLIC OF KOREA**Product: Low voltage switchgear combination
(Terminal block)**

This EC-Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA0122647



Date, 2007-07-11



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2

**EC-Attestation of Conformity**

No. N8 07 07 54505 035

Model(s):

- 1) KH-61 x: Fixture Type
x. Rated current
30: 30 A
60: 60 A
- 2) KH-65 y: Assembly Type
y. Rated current
100: 100 A
200: 200 A
350: 350 A
- 3) KH-6215: Double stack assembly Type
- 4) KH-61 z S: Assembly Type (Rail fixing)
z. Rated current
10: 10 A
15: 15 A
20: 20 A

Parameters:

| | |
|--|------------|
| Rated input voltage: | 600 V a.c. |
| Rated frequency: | 50/60 Hz |
| Pollution degree: | 3 |
| Overtoltage category: | III |
| Rated impulse withstand voltage(Uimp): | 6 KV |

**Tested
according to:**

EN 60947-1:2004
EN 60947-7-1:2002