



Product Service

# EC-Attestation of Conformity

No. N8 07 11 54505 040

**Holder of Certificate:** KUN HUNG ELECTRIC CO., LTD.

113-4, Jangan-Dong, Dongdaemoon-Gu  
SEOUL 130-100  
REPUBLIC OF KOREA

**Product:** Emergency switch off  
(Emergency Stop Switch)

This EC-Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** CPSA0138227



**Date,** 2007-12-03



After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.



Product Service

## EC-Attestation of Conformity

No. N8 07 11 54505 040

### Model(s):

KH - 2201ER - x y z  
 x. Number of NO contacts  
 1 to 4: SPDT - NO  
 y. Number of NC contacts  
 1 to 4: DPDT - NC  
 z. Button cap color  
 R: Red  
 G: Green  
 Y: Yellow  
 B: Blue  
 W: White  
 BK: Black

### Parameters:

Rated input voltage:	125/250 V a.c.
Rated input current:	10 A/ 6 A
Rated insulation voltage:	250 V a.c./d.c
Rated impulse withstand voltage:	4 kV
Utilization category:	AC-15
Degree of protection:	IP50
Pollution degree:	3
Overvoltage category:	III
Number of operating cycles:	100000 (electrical) 1000000 (mechanical)
Rated Conditional Short-circuit current:	1 KA
Remark:	When installing/inserting the equipment all requirements of the mentioned test standards must be fulfilled.

### Tested according to:

EN 60947-1:2004  
 EN 60947-5-1:2004  
 EN 60947-5-5:2005  
 EN 60825-1:2001