



Product Service

EC-Attestation of Conformity

No. N8 07 11 54505 038

Holder of Certificate: KUN HUNG ELECTRIC CO., LTD.113-4, Jangan-Dong, Dongdaemoon-Gu
SEOUL 130-100
REPUBLIC OF KOREA**Product:** Low voltage switchgear combination
(Select Switch)

This EC-Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA0138167**Date,** 2007-12-03

After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



EC-Attestation of Conformity

No. N8 07 11 54505 038

Model(s):

- KH - 2202 - x - y z
- x. Operation part type
- 2S: 2-step manual short lever
 - 3S: 3-step manual short lever
 - 2L: 2-step manual long lever
 - 3L: 3-step manual long lever
 - 2AS: 2-step automatic short lever
 - 3AS: 3-step automatic short lever
 - 3RS: 3-step left-manual, right-automatic short lever
 - 2AL: 2-step automatic long lever
 - 3AL: 3-step automatic long lever
 - 3RL: 3-step left-manual, right-automatic long lever
 - 2K: 2-step manual key switch
 - 3K: 3-step manual key switch
 - 2AK: 2-step automatic key switch
 - 3AK: 3-step automatic key switch
 - 3RK: 3-step left-manual, right-automatic key switch
- y. Number of NO contacts
- 1 to 4: SPDT - NO
- z. Number of NC contacts
- 1 to 4: DPDT - NC

Parameters:

Rated input voltage:	125/250 V a.c.
Rated input current:	10 A/ 6 A
Rated insulation voltage:	250 V a.c./d.c
Rated impulse withstand voltage:	4 kV
Utilization category:	AC-12 (Resistive)
Degree of protection:	IP50
Pollution degree:	3
Overvoltage category:	III
Number of operating cycles:	100000 (electrical) 1000000 (mechanical)
Rated Conditional Short-Circuit Current:	1 KA
Remark:	
When installing/inserting the equipment all requirements of the mentioned test standards must be fulfilled.	

Tested according to:

EN 60947-1:2004
EN 60947-5-1:2004