

## **EC-Attestation of Conformity**

No. N8 07 11 54505 042

Holder of Certificate: KUN HUNG ELECTRIC CO., LTD.

113-4, Jangan-Dong, Dongdaemoon-Gu

SEOUL 130-100 REPUBLIC OF KOREA

Product: Low voltage switchgear combination

(Pilot Lamp)

This EC-Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.:

CPSA0138267



Date, 2007-12-03

After preparation of the necessary technical documentation as well as the conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



110/220/230 V a.c.

250 V a.c./d.c

4 KV

IP56

3 Ш

## **EC-Attestation of Conformity** No. N8 07 11 54505 042

Model(s):

KH - 2203 wx - y z

w. Lamp Cap Type

F: Flat R: Round x. Lamp type

Blank: Incandesent lamp

L: LED lamp

y. Input voltage of lamp 1A: 110 V a.c.; 50/60 Hz 2A: 220 V a.c.; 50/60 Hz 3A: 230 V a.c.; 50/60 Hz

TL: 6 V a.c./d.c.; 6.3 V a.c./d.c.

12 V a.c./d.c. 24 V a.c./d.c.

z. Lamp color

R: Red G: Green Y: Yellow O: Orange

W: White B: Blue

**Parameters:** 

Rated input voltage:

Rated insulation voltage:

Rated impulse withstand voltage: Degree of protection:

Pollution degree: Overvoltage category:

Remark:

When installing/inserting the equipment

all requirements of the mentioned test standards

must be fulfilled.

**Tested** according to:

EN 60947-1:2004 EN 60947-5-1:2004 EN 60825-1:2001

Page 2 of 2