




Product Service

Attestation of Conformity

No. N8 09 11 54505 052

Holder of Certificate: KUN HUNG ELECTRIC CO., LTD.113-4, Jangan-Dong, Dongdaemoon-Gu
SEOUL 130-100
REPUBLIC OF KOREA**Product: Low voltage switchgear combination
(Square Light)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: CPSA0142469**Date,** 2009-11-26
(James Jeon)

After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2

**Attestation of Conformity**

No. N8 09 11 54505 052

Model(s):

KH – 50xL – y

Remark : "x" stands for LED unit size and can be 30 and 40,
"y" stands for rated input voltage and can be 12, 24,
12PCK, 24PCK, D48PCK, D110PCK, 12NCK, 24NCK,
D48NCK, D110NCK, D48T, D110T, D125T, 12T, 22T

Parameters:

Rated input voltage:	12/24/48/110/125 V d.c. 110/220 V a.c.
Rated insulation voltage:	250 V a.c./d.c.
Degree of protection:	IPX0(ordinary)
Pollution degree:	3
Overvoltage category:	III

Remark:

When installing/inserting the equipment
all requirements of the mentioned test standards
must be fulfilled.

**Tested
according to:**

EN 60947-1:2004
EN 60947-5-1:2004
EN 60825-1:2001