



Product Service

# Attestation of Conformity

No. N8 11 08 54505 056

**Holder of Certificate: KUN HUNG ELECTRIC CO., LTD.**113-4, Jangan-Dong, Dongdaemoon-Gu  
SEOUL 130-100  
REPUBLIC OF KOREA**Product: Pushbutton switches  
(Pushbutton switch)**

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2006/95/EC relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** CPSA0128861**Date,** 2011-08-19

( James Jeon )



After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 2



Product Service

**Attestation of Conformity****No. N8 11 08 54505 056****Model(s):****KH-203, KH-203-2****Parameters:**

Rated input voltage:	250/380 V a.c.
Rated input current:	10 A/3 A
Rated insulation voltage:	250 V a.c./d.c
Rated impulse withstand voltage:	4 kV
Utilization category:	AC-12 (Resistive)
Degree of protection:	IP40
Pollution degree:	3
Overvoltage category:	III
Number of operating cycles:	100,000 (Resistive)
Rated Conditional Short-Circuit Current:	1 KA

**Remark:**

When installing/inserting the equipment  
all requirements of the mentioned test standards  
must be fulfilled.

**Tested  
according to:**

EN 60947-1/A1:2011  
EN 60947-5-1/A1:2009