Report No. : H23034E-3 9th May, 2003

TEST REPORT

ON

Illuminated Push Button Switch

Note : 1. This report is valid for fhe apparatus. 2. Only the original report is guaranteed.

KOREA INSTITUTE OF MACHINERY AND MATERIALS INDUSTRIAL SAFETY RESEARCH CENTER 29-1, SECHUL-LI, BAEBANG-MYUN, ASAN-CITY, CHUNGCHEONGNAM-DO, 336-795, KOREA TELEPHONE : (041) 540-5357 FAX : (041) 540-5360 E-mail : choibs@office.hoseo.ac.kr

원보은 상인서 플레이 ...

KOREA INSTITUTE **OF MACHINERY &** MATERIALS(KIMM)

An independent, government designated, nonprofit

institute for ship safety

TEST CERTIFICATE

OF

ELECTRICAL APPARATUS FOR EXPLOSIVE GAS ATMOSPHERES (Issued under Authority vested by the Government of Republic of Korea)

| Cert. No. : EX23IP908 | Date : 9th May, 2003 | | | | |
|---------------------------|---|--|--|--|--|
| Description of apparatus | ription of apparatus : Illuminated Push Button Switch | | | | |
| Model(Type) | : KBL25W Series, KBL30WSeries | | | | |
| Manufacturer(name) | : KUN HUNG ELECTRIC CO., LTD. | | | | |
| (address) | : #113-4, Changan-dong, Dongdaemoon-ku, Seoul, Korea | | | | |
| Drawing No. | : PL-25M-012 | | | | |
| Manufacturer's serial No. | : not applicablle | | | | |

THIS IS TO CERTIFY that the above mentioned apparatus has been tested and inspected by KIMM in accordance with the standard of IEC 60529 and has been found to comply with the requirements of the standard.

Type of protection : IP65 Test report No. : KIMM No. H23034E-3

Marking

: KIMM No. EX23IP908, IP65

B. S. Choi

Beom - Shik Choi

Engineer, Explosion Proof Department, Industrial Safety Research Center

MACHIN OREA GIVIN

OF

Chun-Ha Lee, Ph. D.

Director, Explosion Proof Department, Industrial Safety Research Center

Mailing Address : KOREA INSTITUTE OF MACHINERY & MATERIALS(KIMM) / INDUSTRIAL SAFETY CENTER / 29-1, SECHUL-RI, BAEBANG-MYUN, ASAN-KUN, CHUNGCHEONGNAM-DO, 336-795, KOREA, Phone: (041)540-5357~9, FAX: (041)540-5360, email: choibs@office.hoseo.ac.kr 2003EX-V-S-01

TEST REPORT

Date : 9th May, 2003

| 1. Name of test | Dust & Water Protection Test | |
|---|--|--|
| Applicant (name) (address) Manufacturer | KUN HUNG ELECTRIC CO., LTD. #113-4, Changan-dong, Dongdaemoon-ku, Seoul, Korea ditto | |
| 4. Test specimen 1) Name 2) Model(Type) 3) Type of protection 4) Construction | , | |
| 5. Applied Standard | : IEC 60529 | |
| 6. Test Period | : 1st May, 2003 ~ 9th May, 2003 | |
| 7. Test Result : Test specimen satisfied the performance criteria in IEC-Pub. 60529 (Refer to test results of Appendix 1.) | | |

This is to certify that the above mentioned test have been properly carried out.

Tested by :

Approved by :

B. S. Choi

Beom-Shik, Choi Engineer, Explosion Proof Department, Industrial Safety Research Center

100

Chun-Ha Lee, Ph. D. Director, Explosion Proof Department Industrial Safety Research Center

(This report consists of 5 pages)

Appendix 1.

TEST RESULTS

| Test Item | Tested | Results | Remarks |
|----------------------------------|--------|--------------|----------------------|
| I. Degree of protection | | | |
| 1. First characteristic numeral | 0 | Satisfactory | Refer to Appendix 2. |
| 2. Second characteristic numeral | 0 | Satisfactory | Refer to Appendix 3. |
| II. Marking | 0 | Satisfactory | IP65 |
| | | 8 | |
| | | | |
| | | | |
| | | | |
| | | 14 | |

Test results for dust protection (first characteristic numeral 6)

Description of test

1. Degree of protection : No ingress of dust.

2. Testing method :

The test was made using equipment incorporating with the principles in which talcum powder was maintained in suspension in a suitable closed test chamber. The talcum powder used should pass a square-meshed sieve whose nominal wire diameter was 50μ m and the nominal width between wires was 75μ m. The amount of talcum powder was 2kg per cubic meter of the chamber volume.

The equipment under test was supported in its normal operating position inside the test chamber, but is not connected to a vacuum pump. Any drain-hole normally open shall be left open for the duration of test. The test shall be continued for a period of 8h.

3. Test results : No ingress of dust

Test results for water protection (second characteristic numeral 5)

Description of test

1. Degree of protection :

Water from projected by a nozzle against the enclosure from any direction shall have no harmful effect.

2. Testing method :

The test was made by spraying the enclosure from all practicable directions with a stream of water from a standard test nozzle.

The conditions were as follows.

- nozzle internal diameter : 6.3mm;

– delivery rate : 12.5 ℓ / min \pm 5%;

- water pressure : to be adjusted to achieve the specified delivery rate;
- test duration per square metre of enclosure surface area likely to be sprayed
 1min;
- minimum test duration : 3 min;

- distance from the nozzle to the machine surface : approximately 3m.

3. Test results : No Harmful immersion was found

